The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

REPORT TYPE CODE	CITYTOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOCATION ID	SAMPLE LOCATION NAME	SAMPLE COMMENTS	ANALYTE NAME	RESULT	UNITS OF MEASUREMENT	METHOD DETECTION LIMIT	ANALYTICAL METHOD USED	ANALYSIS LAB	LAB SAMPLE ID	ANALYSIS COMMENTS	SAMPLER NAME	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	REPORT DATE
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	001F	Main Office Foutain		COPPER	0.023	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 2		JP	10/4/2016	07:07:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	001F	Main Office Foutain		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 2		JP	10/4/2016	07:07:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	001P	Main Office Foutain		COPPER	0.025	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 1		JP	10/4/2016	07:06:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	001P	Main Office Foutain		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 1		JP	10/4/2016	07:06:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	002F	Main Office Water Cooler		COPPER	0.42	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 4		JP	10/4/2016	07:08:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	002F	Main Office Water Cooler		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 4		JP	10/4/2016	07:08:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	002P	Main Office Water Cooler		COPPER	0.82	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 3		JP	10/4/2016	07:07:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	002P	Main Office Water Cooler		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 3		JP	10/4/2016	07:07:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	003F	Cafe WC by Kitchen		COPPER	0.26	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 6		JP	10/4/2016	07:04:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	003F	Cafe WC by Kitchen		LEAD	0.003	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 6		JP	10/4/2016	07:04:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	003P	Cafe WC by Kitchen		COPPER	0.34	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 5		JP	10/4/2016	07:04:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	003P	Cafe WC by Kitchen		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 5		JP	10/4/2016	07:04:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	005F	Gym Bubbler		COPPER	0.066	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 8		JP	10/4/2016	07:10:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	005F	Gym Bubbler		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 8		JP	10/4/2016	07:10:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	005P	Gym Bubbler		COPPER	0.23	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 7		JP	10/4/2016	07:09:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	005P	Gym Bubbler		LEAD	0.001	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 7		JP	10/4/2016	07:09:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	006F	Kitchen Kettle		COPPER	0.16	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 10		JP	10/4/2016	05:47:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	006F	Kitchen Kettle		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 10		JP	10/4/2016	05:47:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	006P	Kitchen Kettle		COPPER	0.34	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 9		JP	10/4/2016	05:46:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	006P	Kitchen Kettle		LEAD	0.062	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 9		JP	10/4/2016	05:46:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	007F	Island Food Prep Sink		COPPER	0.11	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 12		JP	10/4/2016	07:02:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	007F	Island Food Prep Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 12		JP	10/4/2016	07:02:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	007P	Island Food Prep Sink		COPPER	0.25	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 11		JP	10/4/2016	07:01:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	007P	Island Food Prep Sink		LEAD	0.001	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 11		JP	10/4/2016	07:01:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	008P	Nurse Foutain		COPPER	0.052	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 13		JP	10/4/2016	07:12:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	008P	Nurse Foutain		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 13		JP	10/4/2016	07:12:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	009F	Nurse Sink		COPPER	0.16	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 15		JP	10/4/2016	07:13:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	009F	Nurse Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 15		JP	10/4/2016	07:13:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	009P	Nurse Sink		COPPER	0.31	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 14		JP	10/4/2016	07:13:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	009P	Nurse Sink		LEAD	0.003	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 14		JP	10/4/2016	07:13:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	010F	Room 2 Sink		COPPER	0.17	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 17		JP	10/4/2016	07:16:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	010F	Room 2 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 17		JP	10/4/2016	07:16:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	010P	Room 2 Sink		COPPER	0.19	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 16		JP	10/4/2016	07:15:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	010P	Room 2 Sink		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 16		JP	10/4/2016	07:15:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	011F	Room 3 Sink		COPPER	0.19	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 19		JP	10/4/2016	07:17:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	011F	Room 3 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 19		JP	10/4/2016	07:17:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	011P	Room 3 Sink		COPPER	0.73	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 18		JP	10/4/2016	07:17:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	011P	Room 3 Sink		LEAD	0.005	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 18		JP	10/4/2016	07:17:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	012F	Room 4 Sink		COPPER	0.2	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 21		JP	10/4/2016	07:19:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	012F	Room 4 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 21		JP	10/4/2016	07:19:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	012P	Room 4 Sink		COPPER	0.24	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 20		JP	10/4/2016	07:18:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	012P	Room 4 Sink		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 20		JP	10/4/2016	07:18:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	013F	Room 5 Sink		COPPER	0.22	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 23		JP	10/4/2016	07:28:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	013F	Room 5 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 23		JP	10/4/2016	07:28:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	013P	Room 5 Sink		COPPER	0.59	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 22		JP	10/4/2016	07:27:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	013P	Room 5 Sink		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 22		JP	10/4/2016	07:27:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	014F	Room 15 Sink		COPPER	0.28	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 25		JP	10/4/2016	07:50:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	014F	Room 15 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 25		JP	10/4/2016	07:50:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	014P	Room 15 Sink		COPPER	0.25	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 24		JP	10/4/2016	07:49:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	014P	Room 15 Sink		LEAD	0.003	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 24		JP	10/4/2016	07:49:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	015F	Room 6 Sink		COPPER	0.24	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 27		JP	10/4/2016	07:32:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	015F	Room 6 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 27		JP	10/4/2016	07:32:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	015P	Room 6 Sink		COPPER	0.41	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 26		JP	10/4/2016	07:31:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	015P	Room 6 Sink		LEAD	0.005	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 26		JP	10/4/2016	07:31:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	016F	Bubbler by Room 7		COPPER	0.21	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 29		JP	10/4/2016	07:34:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	016F	Bubbler by Room 7		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 29		JP	10/4/2016	07:34:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	016P	Bubbler by Room 7		COPPER	0.38	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 28		JP	10/4/2016	07:33:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	016P	Bubbler by Room 7		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 28		JP	10/4/2016	07:33:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	017P	Fountain by Room 7		COPPER	0.007	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 30		JP	10/4/2016	07:34:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	017P	Fountain by Room 7		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 30		JP	10/4/2016	07:34:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	018F	Room 7 Sink		COPPER	0.28	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 32		JP	10/4/2016	07:36:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	018F	Room 7 Sink		LEAD	0.001	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 32		JP	10/4/2016	07:36:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	018P	Room 7 Sink		COPPER	0.54	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 31		JP	10/4/2016	07:35:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	018P	Room 7 Sink		LEAD	0.007	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 31		JP	10/4/2016	07:35:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	019F	Room 8 Sink		COPPER	0.28	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 34		JP	10/4/2016	07:38:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	019F	Room 8 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 34		JP	10/4/2016	07:38:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	019P	Room 8 Sink		COPPER	0.32	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 33		JP	10/4/2016	07:37:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	019P	Room 8 Sink		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 33		JP	10/4/2016	07:37:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	020F	Room 9 Sink		COPPER	0.27	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 36		JP	10/4/2016	07:39:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	020F	Room 9 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 36		JP	10/4/2016	07:39:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	020P	Room 9 Sink		COPPER	0.32	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 35		JP	10/4/2016	07:38:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	020P	Room 9 Sink		LEAD	0.006	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 35		JP	10/4/2016	07:38:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	021F	Room 10 Slnk		COPPER	0.28	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 38		JP	10/4/2016	07:42:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	021F	Room 10 Slnk		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 38		JP	10/4/2016	07:42:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	021P	Room 10 Slnk		COPPER	0.5	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 37		JP	10/4/2016	07:41:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	021P	Room 10 Slnk		LEAD	0.004	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 37		JP	10/4/2016	07:41:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	022F	Room 11 Sink		COPPER	0.67	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 40		JP	10/4/2016	07:44:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	022F	Room 11 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 40		JP	10/4/2016	07:44:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	022P	Room 11 Sink		COPPER	0.75	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 39		JP	10/4/2016	07:43:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	022P	Room 11 Sink		LEAD	0.001	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 39		JP	10/4/2016	07:43:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	023F	Room 12 Sink		COPPER	0.38	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 42		JP	10/4/2016	07:46:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	023F	Room 12 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 42		JP	10/4/2016	07:46:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	023P	Room 12 Sink		COPPER	0.53	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 41		JP	10/4/2016	07:45:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	023P	Room 12 Sink		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 41		JP	10/4/2016	07:45:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	024F	Art Room Sink - Left		COPPER	0.4	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 44		JP	10/4/2016	05:59:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	024F	Art Room Sink - Left		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 44		JP	10/4/2016	05:59:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	024P	Art Room Sink - Left		COPPER	0.32	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 43		JP	10/4/2016	05:58:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	024P	Art Room Sink - Left		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 43		JP	10/4/2016	05:58:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	025F	Fountain by Room 17		COPPER	0.2	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 46		JP	10/4/2016	06:03:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	025F	Fountain by Room 17		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 46		JP	10/4/2016	06:03:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	025P	Fountain by Room 17		COPPER	0.28	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 45		JP	10/4/2016	06:02:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	025P	Fountain by Room 17		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 45		JP	10/4/2016	06:02:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	026F	Room 16 Sink		COPPER	0.16	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 48		JP	10/4/2016	06:07:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	026F	Room 16 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 48		JP	10/4/2016	06:07:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	026P	Room 16 Sink		COPPER	0.14	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 47		JP	10/4/2016	06:06:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	026P	Room 16 Sink		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 47		JP	10/4/2016	06:06:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	028F	Room 18 Sink		COPPER	0.45	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 50		JP	10/4/2016	06:10:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	028F	Room 18 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 50		JP	10/4/2016	06:10:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	028P	Room 18 Sink		COPPER	0.53	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 49		JP	10/4/2016	06:09:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	028P	Room 18 Sink		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 49		JP	10/4/2016	06:09:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	029F	Room 21 Sink		COPPER	1.08	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 52		JP	10/4/2016	06:12:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	029F	Room 21 Sink		LEAD	0.001	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 52		JP	10/4/2016	06:12:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	029P	Room 21 Sink		COPPER	1.15	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 51		JP	10/4/2016	06:11:00	19-Oct-16

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

REPORT TYPE CODE	CITYTOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOCATION ID	SAMPLE LOCATION NAME	SAMPLE COMMENTS	ANALYTE NAME	RESULT	UNITS OF MEASUREMENT	METHOD DETECTION LIMIT	ANALYTICAL METHOD USED	ANALYSIS LAB	LAB SAMPLE ID	ANALYSIS COMMENTS	SAMPLER NAME	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	REPORT DATE
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	029P	Room 21 Sink		LEAD	0.003	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 51		JP	10/4/2016	06:11:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	030F	Room 20 Sink		COPPER	0.74	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 54		JP	10/4/2016	06:14:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	030F	Room 20 Sink		LEAD	0.001	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 54		JP	10/4/2016	06:14:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	030P	Room 20 Sink		COPPER	0.7	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 53		JP	10/4/2016	06:13:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	030P	Room 20 Sink		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 53		JP	10/4/2016	06:13:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	032F	Room 22 Sink		COPPER	0.27	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 56		JP	10/4/2016	06:18:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	032F	Room 22 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 56		JP	10/4/2016	06:18:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	032P	Room 22 Sink		COPPER	0.28	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 55		JP	10/4/2016	06:17:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	032P	Room 22 Sink		LEAD	0.004	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 55		JP	10/4/2016	06:17:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	033F	Room 23 Sink		COPPER	0.19	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 58		JP	10/4/2016	06:21:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	033F	Room 23 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 58		JP	10/4/2016	06:21:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	033P	Room 23 Sink		COPPER	0.19	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 57		JP	10/4/2016	06:20:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	033P	Room 23 Sink		LEAD	0.003	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 57		JP	10/4/2016	06:20:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	034F	Room 24 Sink		COPPER	0.34	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 60		JP	10/4/2016	06:22:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	034F	Room 24 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 60		JP	10/4/2016	06:22:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	034P	Room 24 Sink		COPPER	0.42	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 59		JP	10/4/2016	06:21:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	034P	Room 24 Sink		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 59		JP	10/4/2016	06:21:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	035F	Room 25 Sink		COPPER	0.21	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 62		JP	10/4/2016	06:24:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	035F	Room 25 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 62		JP	10/4/2016	06:24:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	035P	Room 25 Sink		COPPER	0.62	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 61		JP	10/4/2016	06:23:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	035P	Room 25 Sink		LEAD	0.001	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 61		JP	10/4/2016	06:23:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	036F	Room 27 Sink		COPPER	0.61	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 64		JP	10/4/2016	06:27:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	036F	Room 27 Sink		LEAD	0.091	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 64		JP	10/4/2016	06:27:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	036P	Room 27 Sink		COPPER	0.41	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 63		JP	10/4/2016	06:20:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	036P	Room 27 Sink		LEAD	0.713	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 63		JP	10/4/2016	06:20:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	037F	Room 26 Sink		COPPER	0.61	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 66		JP	10/4/2016	06:29:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	037F	Room 26 Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 66		JP	10/4/2016	06:29:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	037P	Room 26 Sink		COPPER	0.55	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 65		JP	10/4/2016	06:28:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	037P	Room 26 Sink		LEAD	0.013	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 65		JP	10/4/2016	06:28:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	039P	Preschool Sink left		COPPER	0.3	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 67		JP	10/4/2016	06:47:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	039P	Preschool Sink left		LEAD	0.003	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 67		JP	10/4/2016	06:47:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	040F	Preschool Sink right		COPPER	0.23	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 69		JP	10/4/2016	06:48:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	040F	Preschool Sink right		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 69		JP	10/4/2016	06:48:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	040P	Preschool Sink right		COPPER	0.29	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 68		JP	10/4/2016	06:47:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	040P	Preschool Sink right		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 68		JP	10/4/2016	06:47:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	041P	Art Room Sink Right-P		COPPER	0.34	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 70		JP	10/4/2016	05:58:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	041P	Art Room Sink Right-P		LEAD	0.004	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 70		JP	10/4/2016	05:58:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	042F	Room 17 Sink-F		COPPER	0.43	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 72		JP	10/4/2016	06:05:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	042F	Room 17 Sink-F		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 72		JP	10/4/2016	06:05:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	042P	Room 17 Sink-P		COPPER	0.61	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 71		JP	10/4/2016	06:04:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	042P	Room 17 Sink-P		LEAD	0.014	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 71		JP	10/4/2016	06:04:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	043P	Room 22 Bubbler-P		COPPER	0.41	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 73		JP	10/4/2016	06:11:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	043P	Room 22 Bubbler-P		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 73		JP	10/4/2016	06:11:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	044P	Room 27 Bubbler		COPPER	0.74	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 74		JP	10/4/2016	06:26:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	044P	Room 27 Bubbler		LEAD	0.936	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 74		JP	10/4/2016	06:26:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	045P	Room 26 Bubbler-P		COPPER	0.76	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171323 75		JP	10/4/2016	06:28:00	19-Oct-16
LCCA	Manchester	06980010	Manchester Essex Regional: Manchester Memorial Elementary	Public School	045P	Room 26 Bubbler-P		LEAD	0.01	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171323 75		JP	10/4/2016	06:28:00	19-Oct-16